


Split-core AC Current Transformer (CTV-x) (AC Amperage to DC Voltage Transducer)



For use with HOBOb® U12, UX120-06M, MX1104, and MX1105 data loggers and HOBOb ZW data nodes

Specifications

| | |
|-------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Current Range | CTV-A 2–20 AMPS AC CTV-B 5–50 AMPS AC CTV-C 10–100 AMPS AC CTV-D 20–200 AMPS AC CTV-E 60–600 AMPS AC |
| Accuracy with U12 | ±4.5% of full scale (includes logger accuracy) |
| Accuracy with ZW | ±4.0% of full scale (includes data node accuracy) |
| Accuracy with UX120-006M, MX1104, and MX1105 | ±2.1% of full scale (includes logger accuracy) |
| Response time (from 10% to 90% of amplitude): | CTV-A approx. 440 milliseconds CTV-B approx. 200 milliseconds CTV-C approx. 100 milliseconds CTV-D approx. 450 milliseconds CTV-E approx. 490 milliseconds |
| Input Current | AC current, sine wave, single phase 50 Hz or 60 Hz, load power factor 0.5 to 1.0 lead or lag |
| Output | 0-2.5 V DC |
| Voltage rating | 600 V AC |
| Temperature rating | CTV-A, CTV-B, CTV-C: -15° to 60°C (5° to 140°F), CTV-D, CTV-E: -15° to 40°C (5° to 104°F) |
| Construction | Molded plastic housing for indoor use per UL508 |
| Cable | 1.8 m (6 ft.) |
| Window Size | CTV-A, CTV-B, CTV-C: 28 x 20 mm (1.1 x 0.8 in.) CTV-D: 39 x 32 mm (1.54 x 1.26 in.) CTV-E: 74 x 62 mm (2.92 x 2.46 in.) |
| Dimensions | CTV-A, CTV-B, CTV-C: 79 x 71 x 36 mm (3.1 x 2.8 x 1.4 in.) CTV-D: 100 x 120 x 29 mm (3.92 x 4.72 x 1.14 in.) CTV-E: 135 x 150 x 28 mm (5.3 in. x 5.91 in. x 1.12 in.) |
|  | The CE Marking identifies this product as complying with all relevant directives in the European Union (EU) |

Notice

- This product is not intended for life or safety applications.
- Do not install this product in hazardous or classified locations.
- The installer is responsible for conformance to all applicable codes.
- Mount this product inside a suitable fire and electrical enclosure.



DANGER

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

Failure to follow these instructions will result in death or serious injury.



- Follow safe electrical work practices.
- See NFPA 70E in the USA, or applicable local codes.
- This equipment must only be installed and serviced by qualified electrical personnel.
- Read, understand and follow the instructions before installing this product.
- Turn off all power supplying equipment before working on or inside the equipment.
- Use a properly rated voltage sensing device to confirm power is off.
- DO NOT DEPEND ON THIS PRODUCT FOR VOLTAGE INDICATION

Specification Note: For CE compliance, conductor shall be insulated according to IEC 61010-1:2001, Installation Category III or equivalent. The product design provides for basic insulation only.

Using the CTV with the HOBOb logger or data node

1. Insert the 2.5 mm plug of the CTV into an external input of a logger or node.
 - For MX1104 and MX1105 loggers, select the appropriate sensor type in the app when you are configuring the logger.
 - For U12 and UX120-006M loggers, select the appropriate channel in the Launch Logger window in HOBObware.
 - For a ZW data node, open HOBObnode Manager in HOBObware and select the sensor type (-A, -B, etc.) in the Configure Sensor pane that matches the Current Transformer model number.
2. If working with HOBObware, select the correct AC current range, which is provided on the CTV label. Failure to select the correct range will result in inaccurate data. **Do not exceed the AC current rating of the CTV.**

Installation

- The I-bar can be hinged open in order to install the CTV around an individual wire carrying a single phase. Rotate the I-bar open (on the CTV-D and -E units, press in the I-bar tabs to open). Place the wire in the CTV window and then snap the I-bar closed.
- The I-bar on the CTV-D and CTV-E units is fully removable for easy installation. Make sure the I-bar is replaced in the proper orientation to ensure correct readings. The contacts on the unit and I-bar are marked with matching notations.
- The CTV-A, -B, and -C units are provided with a snap-on mounting plate which can be removed from the CTV and mounted separately. Mount the plate under the wire you want to monitor and, once the cable is installed into the CTV, snap the CTV/wire assembly onto the mounting plate.
- Remove the CTV from the plate by opening the CTV and sliding it off the plate or gently rocking the CTV slightly and pulling up at the same time.

